



AAMA / WDMA / CSA JOINT TECHNICAL INTERPRETATION REQUEST

DATE OF INQUIRY:

January 19, 2015

INTERPRETATION
NUMBER
15-02

PERTINENT JOINT AAMA/WDMA/CSA SPECIFICATION(S):

AAMA/WDMA/CSA 101/I.S.2/A440-08
AAMA/WDMA/CSA 101/I.S.2/A440-11

SECTION(S) IN QUESTION:

NAFS-08:

Clause 3 Definition Water Penetration
Clause 5.2.5 Test specimen installation
Figure 11

NAFS-11:

Clause 3 Definition Water Penetration
Clause 8.4.3 Test specimen installation (skylights)
Figure 8.2
Clause 9.2.5 Test specimen installation
Figure 9.2

INTERPRETATION REQUESTED:

1) Under NAFS-08 and NAFS-11, is any form of liquid water (including percolating water) beyond the inner-most plane, independent of amount or means of occurrence considered water penetration as defined by ASTM E331 and E547?

SUGGESTED INTERPRETATION:

1) Yes.

REVIEWED/ APPROVED BY:

COMMITTEE	COMMENTS / ACTION	STATUS	DATE
JDMG		Approved	11/9/15
AAMA		Approved	4/1/2015
CSA		Approved	10/15/2015
WDMA		Approved	7/15/2015