



AAMA / WDMA / CSA JOINT TECHNICAL INTERPRETATION REQUEST

DATE OF INQUIRY:

January 19, 2015

INTERPRETATION
NUMBER
15-03

PERTINENT JOINT AAMA/WDMA/CSA SPECIFICATION(S):

AAMA/WDMA/CSA 101/I.S.2/A440-11

SECTION(S) IN QUESTION:

Clause 1.1 General (f) folding door systems

NAFS-11 states that folding door systems were not intended to be tested to this standard/specification.

INTERPRETATION REQUESTED:

1) Under NAFS-11 can folding door systems be designated as Specialty Products (SP)? Note that folding door systems were allowed to be designated as SP in NAFS-08.

SUGGESTED INTERPRETATION:

1) Yes. For folding door systems only, the statement in Clause 1.1 does not preclude the use of the Specialty Products (SP) designation as per Clause 12.4.1.

REVIEWED/ APPROVED BY:

COMMITTEE	COMMENTS / ACTION	STATUS	DATE
JDMG		Approved	11/9/2015
AAMA		Approved	4/1/2015
CSA		Approved	10/15/2015
WDMA		Approved	7/15/2015